

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1574:124 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Models ADT276A-REL and ADT 278A-REL manual pull stations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as non-coded fire alarm pull stations for use with separately listed compatible fire alarm control units.

NOTE: Models provided with two-wire lead and normally closed switch contacts are not approved for fire alarm signaling use.

XLF: 7150-1591:111

11-22-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 2, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager